



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7167-0992:0504
PARENT LISTING No.:	7167-2408:0001
CATEGORY:	7167 - CONTROL UNIT (HOUSEHOLD)
LISTEE:	Napco 333 Bayview Avenue, Amityville, NY, 11701 Contact: Lemma, Frank 631-842-9400 Email: flemma@napcosecurity.com
DESIGN:	<p>Prima Model PP1A and PP1V, for residential, indoor use, cord-connected Wireless Burglar-Alarm/Fire/Health Warning Unit uses 433Mhz short range radio frequency and WiFi 802.11 a/b/g/n/ac dual band 2.4/5G with built-in router capability for interconnection and communication. The unit can be configured as a wall mounted unit or a desktop unit. The product receives power from an UL listed Class 2 direct plug-in power supply. The unit also receives secondary power from a rechargeable lithium-ion battery pack.</p> <p>Refer to listee's data sheet for additional detailed product description and operational considerations.</p>
RATING:	<p>Primary Input Power: 100-240VAC, 0.68A max</p> <p>Output Power: 12VDC, 2500mA</p> <p>Secondary Power: Rechargeable lithium-ion battery 3600mAh, 3.7VDC max</p>
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating and ETL label.
APPROVAL:	Listed as combination household fire alarm control unit for use with separately listed compatible initiating and indicating devices. Model complies with UL 985, 6th Edition.
NOTES:	<ol style="list-style-type: none">1. The Fire Alarm Verification Feature (delay of fire alarm signal), not approved for use in California.2. Burglary and other non-fire functions were not examined.

03-02-26 MH



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/04/2026

Listing Expires: 06/30/2026

Authorized By: **Michael Huang** , Program Coordinator
Fire Engineering & Investigations Division